



INTERIOR

NOTES:

THIS DETAIL SHALL BE USED ONLY WHERE APPROVED BY WATER RESOURCES DEPARTMENT.

DROP PIPE USED SHALL BE SAME SIZE AS INLET SEWER PIPE.

DROP PIPE SHALL BE TYPE SDR-35 PVC. A RELINER DROP SYSTEM BY DURAN OR EQUIVALENT MAY BE USED WHERE APPROVED BY THE PUBLIC WORKS DEPARTMENT.

PROPOSED CONNECTION TO BE USED WHERE "X" EXCEEDS 2'-0" FROM INVERT OUT.

DATE: 3/1/14

CITY OF REIDSVILLE

STANDARD INTERIOR DROP CONNECTION FOR  
EXISTING SANITARY SEWER MANHOLE

STD. NO.

REV.

203