



**NOTES:**

- RING AND COVER TO BE USF 669-2 RING & KL-2 COVER OR APPROVED EQUIVALENT.
- ALL DIMENSIONS AND TOLERANCES ARE TO BE CONCENTRIC AND WILL SUPERSEDE ANY ASTM STANDARDS WITH A MAXIMUM VARIATION  $\pm 1/16"$  ON ALL DIMENSIONS.
- MANHOLE RING TO BE ANCHORED WITH 1/2" STAINLESS STEEL EXPANSION ANCHORS AND SEALED BETWEEN RING AND CONE WITH BITUMASTIC SEALER.

DATE: 3/1/14

**CITY OF REIDSVILLE**

STANDARD WATERTIGHT MANHOLE  
RING AND COVER

STD. NO.	REV.
205-B	