



NOTE:

WHEN THE METER AND CLEANOUT ARE LOCATED AT THE IDEAL LOCATION, SIDE BY SIDE AT THE R/W LINE. THE SEPARATION BETWEEN THE WATER METER AND THE SEWER CLEANOUT SHALL BE 18" MINIMUM BETWEEN THE CLOSEST EDGE OF THE WATER METER AND THE CENTER OF THE CLEANOUT PIPE.

SHEET 3 OF 3  
DATE: 3/1/14

C I T Y O F R E I D S V I L L E

HOUSE CONNECTION AND HYDRANT  
SETTING DETAIL – PLAN VIEW

STD. NO.

REV.

101