



SECTION FOR SANITARY SEWER SERVICE

NOTE:

WHEN THE METER AND CLEANOUT ARE LOCATED AT THE IDEAL LOCATION, SIDE BY SIDE AT THE R/W LINE. THE SEPARATION BETWEEN THE WATER METER AND THE SEWER CLEANOUT SHALL BE 18" MINIMUM BETWEEN THE CLOSEST EDGE OF THE WATER METER AND THE CENTER OF THE CLEANOUT PIPE.

SHEET 2 OF 3
DATE: 3/1/14

CITY OF REIDSVILLE

HOUSE CONNECTION AND HYDRANT
SETTING DETAIL

STD. NO.	REV.
101	